

Outputs

Output ports usually have A in their name, e.g. PA, QA, RA, SA, TA.
 Except that ports in the multi-IO card can be programmed as outputs or inputs.
 All values output on a port can be read back. For example
 HEX 55 PA OUT
 PA IN X. result is 0055

Inputs

Output ports usually have B in their name, e.g. PB, QB, RB, SB, TB.
 Except that ports in the multi-IO card can be programmed as outputs or inputs and that card also has ports ending in C. For example:
 PB IN X. result is usually 00FF. However the robot uses the PB port for calibration so you may see a different value.

Standard Outputs and Inputs

	User outputs - 15w D		User inputs - 9w D
1	PA 7	1	PB 6
2	PA 6	2	PB 5
3	PA 5	3	Ovolts
4	PA 4	4	PB 3
5	PA 3	5	+12V
6	PA 2	6	PB 7
7	PA 1 (elec grip)	7	0 volts
8	PA 0 (gripper)	8	PB 4
9	0 volts	9	+12 volts
10	0 volts		
11	+12v		
12	+12v		
13	+12v		
14	+12v		
15	+12v		

PA Outputs

The PA port is the primary output port

All the outputs are open collector Darlingtontons with the zero volts being the same ground as the controller. You can connect a load e.g. a solenoid or a relay between the output pin and +12v, for example a relay to be operated by PA 1 would connect between pin 7 and pin 11.

The gripper is usually connected to port PA bit 0.

Type GRIP to close the gripper, UNGRIP to open.

You can also enter

PA 0 ON to close and PA 0 OFF to open.

PA 0 is defined already as GRIPPER so you can enter

GRIPPER ON and GRIPPER OFF

Note: the electric gripper uses PA 0 and PA 1 so ON and OFF can not be used with the electric gripper.

The same philosophy applies to the other output bits, for example suppose you have a pump connected to PA 2. You could enter

PA 2 ON and PA 2 OFF

Or you could define

: PUMP PA 2 ;

then PUMP ON and PUMP OFF

You can incorporate outputs in a definition that also has robot motion, for example let's assume PA 5 means "warning, robot in motion". You could have connected that output to an illuminated legend with that wording.

For example

```
: WARNING PA 5 ;
```

```
: INITIALIZE
```

```
START
```

```
WARNING ON
```

```
CALIBRATE
```

```
HOME
```

```
WARNING OFF
```

```
;
```

Type INITIALIZE to observe that.

PB inputs

The PB port is the primary input port

Bits 0-4 are used by the calibration sensors of the robot, leaving bits 5,6,7 for the user, although some other inputs may be shared.

Each input has a pullup to +5v. When you read the inputs they should all be '1' unless a robot sensor is sensing.

It is most easily monitored with a command

PP

This continually displays the input in binary e.g.

11111110

From right to left is ascending value (as in decimal) so bit 0 is furthest right and bit 7 is furthest left. Bits 0,1,2,3,4 are used by the robot for calibration and the 3 furthest left are for the user. Hence the proper way to show this display is

111xxxxx

To change an input from 1 to 0 simply 'short' it to 0 with a relay or the open collector output of a proximity detector etc. For example connect pin 6 (bit 7) to pin 7 (0v) and you will see

011xxxxx

Words that use these inputs are IN, WAIT and BIT?

BIT? Takes the specified bit and leaves a true or false. A true can be any value but false is 0.

Example use of WAIT

```
: GREEN-BUTTON PB 5 ;
```

```
: INITIALIZE
```

```
START
```

```
GREEN-BUTTON 0 WAIT
```

```
CALIBRATE
```

```
HOME
```

```
;
```

Example use of BIT? (with two PLACEs)

```
: TASK
```

```
PB 6 BIT? IF
```

```
  JIG1
```

```
ELSE
```

```
  JIG2
```

```
THEN
```

```
;
```

16-bit I/O expansion card

This card has 8 bits of opto-isolated and Darlington buffered outputs and 8 bits of opto-isolated inputs.

There is a jumper on the PC card. With the jumper fitted the ports are SA and SB and with the jumper removed the ports are TA and TB.

If you are not sure which one you have here is a quick check:

HEX 55 SA OUT

SA IN X. result 0055

If the result is 00FF then try TA

The inputs are on a 25 way socket which connects to a 16 way 2 row HE14 connector J4 on the card.

The outputs are in 2 separate groups of 4 each with 1A Darlington drivers which pull down to the common ground for each group. The positive supplies must also be brought to the connectors.

OUTPUTS (SA/TA)

INPUTS (SB/TB)

25w D skt	Function	25w D plug	Function
1	output 7	1	input 7 neg
2	output 6	2	input 6 neg
3	output 5	3	input 5 neg
4	output 4	4	input 4 neg
5	output 3	5	input 3 neg
6	output 2	6	input 2 neg
7	output 1	7	input 1 neg
8	output 0	8	input 0 neg
14	positive supply for outputs 4,5,6,7	14	input 7 pos
15	common ground for outputs 4,5,6,7	15	input 6 pos
16	common ground for outputs 4,5,6,7	16	input 5 pos
17	common ground for outputs 4,5,6,7	17	input 4 pos
18	positive supply for outputs 0,1,2,3	18	input 3 pos
19	common ground for outputs 0,1,2,3	19	input 2 pos
20	common ground for outputs 0,1,2,3	20	input 1 pos
21	common ground for outputs 0,1,2,3	21	input 0 pos

SA/TA Outputs

All the outputs are open collector Darlington transistors with the zero volts being isolated from the controller. You need a separate external 12 or 24v DC supply. There are two sets of 4 outputs each with its own 0v and +v connections. Therefore you can use two separate supplies if you wish or connect one supply to both sets. Connect the + terminal of your supply to pins 14,18 and the – terminal of your supply to pins 15 (and/or16,17) and 19 (and/or 20,21).

You can connect a load e.g. a solenoid or a relay between the output pin and your +v, for example a relay to be operated by SA 1 would connect between pin 7 and pin 14.

SB/TB inputs

The inputs are likewise isolated and require an external supply. You connect your – terminal to one of the negative pins and your load between your + terminal and an output pin. In other words to make an input on SB bit 0 you apply a voltage to pins 8 and 21, pin 8 being the negative and 21 being positive.

The input is most easily monitored with a command similar to PP but PP only applies to PB. Instead use
SB WATCH

This continually displays the input in binary e.g.

11111111

From right to left is ascending value so bit 0 is furthest right and bit 7 is furthest left.

To change an input from 1 to 0 apply a voltage 12-24v between the two pins for that input. For example connect a 24v supply, negative to pin 8, positive to pin 21 and you should see

11111110

All the inputs are independent opto-isolators so you can common up all the + pins if you wish or all the – pins, or use completely independent sources of voltage.

Sharing inputs between user and robot sensors – R17 ONLY.

As you can see from the controller manual section 12 inputs PB 3 and PB 4 are available on the user 9w D connector but these are used by the robot for calibration of axes 4 and 5 (the hand).

	Robot inputs - 25w D		User inputs - 9w D
1	Sensor 1 (PB 0)	1	PB 6
2	Sensor 2 (PB 1)	2	PB 5
3	Sensor 3 (PB 2)	3	Ovolts
4	Sensor 4 (PB 3)	4	PB 3
5	Sensor 5 (PB 4)	5	+12V
6		6	PB 7
7		7	0 volts
8		8	PB 4
9		9	+12 volts
21	Sensor 6 (PB 5)		

When an axis calibrates the input goes low and then high, and remains high except when an axis goes past a sensor in normal motion. Therefore if you use an input PB 3 or 4 on the 9wD you must ensure:

1. That your inputs on the 9w D are high (open) before the robot can calibrate
2. That when you are polling PB 3 or 4 that the hand is not in such a position that PB 3 or 4 are made low by chance position against its sensors.

Don't forget you can check the state of the PB inputs with PP

(press escape to exit PP)

You would be advised to insert the following code in your text file. This redefines CALIBRATE so as to check the shared inputs first:

```

: CALIBRATE
PB 3 BIT? 0=
PB 4 BIT? 0=
OR IF
    ." shared input prevents calibration "
ELSE
    CALIBRATE
THEN
;
    
```